


## 4-12 Measuring Radiation Intensity in Nuclear Reactors

- Developing  $\gamma$ -ray Detectors for Remote Inspection in Primary Containment Vessel -




**Fig.4-26 Schematic of SPGD and irradiation experiment**  
 (a) SPGD is a  $\gamma$ -ray detector with a diameter of only a few millimeters and comprises an emitter, collector, and insulator.  
 (b) Output currents from SPGDs when irradiated under same conditions that were measured by a switching unit and picoammeter.  
 (c) Irradiation conditions were precisely determined by thermocouple and dosimeters positioned near the SPGDs.

The fuel debris must be removed to decommission the TEPCO's Fukushima Daiichi NPS (1F). However, the high-radiation environment precludes a visual confirmation of the primary containment vessel (PCV) at 1F.

Therefore, we are developing a method to measure radiation that uses a self-powered gamma detector (SPGD) as a means to obtain the distribution of the debris in PCVs. The SPGD does not require a complex structure and an external electric power source because the output current is obtained from electrons generated by  $\gamma$ -rays impinging on the emitter. This means that the SPGD can be only a few millimeters in diameter and can therefore access intricate piping systems (Fig.4-26).

To determine the applicability of the SPGD be to 1F, we fabricated thin SPGDs with lead (Pb) emitters of various lengths and diameters, and investigated their  $\gamma$ -ray detection limits. The relationship between the  $\gamma$ -ray intensity and the output current was obtained in irradiation rooms where the  $\gamma$ -ray intensity distribution was known. The results indicate



**Fig.4-27 Output currents of SPGDs with  $\gamma$ -ray-dose rate**  
 (d) Output currents of SPGDs used in this study were proportional to the dose rates up to and over 4000 Gy/h.  
 (e) Lower-detection limit was about 10 Gy/h.

that the length of emitter influences the output current more than the diameter.

Until now, the dose rate in the PCV was considered to be up to tens of gray per hour, with the higher-intensity radiation doubtless occurring closer to the core. In a high-dose-rate environment, the output current was linear in dose rate to over 4000 Gy/h (Fig.4-27(d)). In a low-dose-rate environment, above 10 Gy/h, the average discrepancy with respect to the approximate curve (dashed lines) was estimated to be  $\sim 14\%$ , as indicated by dash-dotted lines (Fig.4-27(e)). Thus, the SPGDs used in this study can measure the  $\gamma$ -ray-dose rate with fair accuracy. These results show that the measuring range of the SPGDs corresponds to the intensity of radiation in the PCV of 1F and that the SPGDs may serve as a detector in such an environment.

By leveraging the results of the present study, we plan to further improve the structure of the SPGDs to increase their sensitivity and their ability to interrogate intricate pipe systems.

### Reference

Takeuchi, T. et al., Development of a Self-Powered  $\gamma$  Detector, Journal of Nuclear Science and Technology, vol.51, issues 7-8, 2014, p.939-943.